



One North Haven St
Baltimore, MD 21224
Ph: 410-732-3500
Fax: 410-327-7443
www.sullivanuv.com

Important Installation Notice:

Temperature Sensors:

The Enclosed Power Management Units (PMU's) generate heat and require adequate airflow to ensure proper cooling. To help monitor these units have been built with non-reversing temperature sensitive stickers affixed to critical areas of the enclosure. Upon receipt of the unit **take note of the condition of the stickers**. They may have some or none of the indicators darkened. The darkened condition indicates the maximum temperature reached during full load power testing at Sullivan.

If additional dots become darkened this indicates the system is being over loaded or is not receiving enough air exchange in its installed location. To avoid permanent damage immediately reduce power consumption (load) and contact Sullivan to resolve the overheating condition.

Sullivan UV
Engineering & Support
410-732-3500
sales@sullivanproducts.com
www.sullivanuv.com